



RINA

EC TYPE EXAMINATION (MODULE B)

CERTIFICATE Nr. MED311711CS/001

This is to certify, that RINA, specified as Notified Body N° 0474 by the Italian "Ministero delle Infrastrutture e dei Trasporti Direzione Generale per la navigazione ed il Trasporto Marittimo ed Interno" on 25 November 1998, did undertake the relevant type approval procedures for the equipment identified below which was found to be in compliance with the Fire Protection requirements of Marine Equipment Directive (MED) 96/98/EC as modified by Directive 2009/26/EC

<i>MED Item N°</i>	A.1/3.2
<i>Description</i>	Portable fire extinguishers
<i>Type</i>	ITALFIRE P6M
<i>Applicant</i>	ITALFIRE S.R.L. ZONA INDUSTRIALE - CONTRADA ACUTI 74024 MANDURIA (TA) ITALY
<i>Testing standards</i>	EN 3-6 (1995)+A1(1999), EN 3-7 (2004) +A1(2007), EN 3-8 (2006)+AC(2007)
<i>Reference standards</i>	Reg II-2/4, Reg II-2/10, Reg II-2/19, Reg II-2/20 SOLAS 74 as amended, IMO Res.A.951(23), IMO Res.MSC 36(63), IMO Res.MSC.97(73), IMO Res.MSC 98(73)-(FSS Code), IMO MSC/Circ.1275

Issued at Genoa on
November 26, 2011


This Certificate is valid until
November 25, 2016

This Certificate consists of this sheet plus an attachment



Francesco Fanciulli

Francesco Fanciulli
RINA

RINA 
Via Corsica, 12 - 16128 Genova
Tel +39 010 53851
Fax +39 010 5351000



RINA

**ATTACHMENT TO
CERTIFICATE Nr. MED311711CS/001**

Page 1 of 2

Manufacturer

ITALFIRE S.R.L.

Place of Manufacturer

ZONA INDUSTRIALE - CONTRADA ACUTI
74024 MANDURIA (TA)
ITALY

Product description

Technical characteristics	
Cylinder material	Steel FeP12 UNI 5867
Outside cylinder diameter	160 mm approx.
Minimum wall thickness	1.5 mm
Cylinder capacity	6.70 dm ³
Weight empty	3.50 kg approx.
Weight full	9.50 kg approx.
Working pressure at 20°C	1.5 N/mm ²
Use limit temperatures	-20°C/ +60°C
Extinguishing agent	6 kg Powder ABC type "POL/FIRE SUPER"
Fire rating	34A - 233B - C

Reference documents

- ITALFIRE S.r.l. drawings and documents filed by RINA with n° FPE-9081 to FPE-9086 on 07/04/2006.
- ITALFIRE S.r.l. drawings approved by RINA with n° FPE-9087 and FPE-9088 on 07/04/2006
- Fire Extinguisher label approved by RINA with n° CSST 7882..

Tests carried out

- T.E.S.I. Test Reports n° 021/B and 004/RINA filed by RINA with n° FPE-9080 on 07/04/2006.




RINA
Via Corsica, 12 - 16128 Genova
Tel +39 010 53851
Fax +39 010 5351000



RINA

**ATTACHMENT TO
CERTIFICATE Nr. MED311711CS/001
Page 2 of 2**

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production control phase module (D, E or F) of Annex B of the Directive is fully complied with a written inspection agreement with a Notified Body



XXXX/YY


"WHEELMARK FORMAT"

XXXX *Notified Body number undertaking surveillance module*
YY *Last two digits of year mark affixed*

General conditions for the approval

- a) The initial conditions verified by RINA at the time of the approval are to be maintained
- b) Any changes to the initial conditions are to be promptly communicated to RINA, which reserves the right to repeat the relevant assessment
- c) This certificate will no be valid if the manufacturer makes any changes or modifications to the approved equipment which have not been notified to, and agreed with RINA
- d) RINA personnel are to be allowed to witness during the performances of activities, upon their request
- e) The activities are to be carried out in compliance with the RINA Rules and/or other applicable Rules
- f) Should the specified regulations or standards be amended during the validity of this certificate, the product is to be reapproved prior to it being placed on board vessels to which the amended regulations or standards apply.





Francesco Fanciulli